

SECTION 07810 CEMENTITIOUS FIREPROOFING *Medium Density Type 7 GP – Exposed*

Scope: *This specification is intended for Type 7 GP for use on structural steel in **exposed environments**, such as parking garages, elevator shafts, mechanical rooms and similar structures where the sprayed fire resistive material may be exposed to contact and potential abuse and/or where partial cover is prevalent. It is not intended for full time permanent outdoor exposure. A/D Fire Protection Systems also manufactures **concealed cementitious** interior fire protection for use in locations not subject to physical contact or abuse and **exterior cementitious** fire protection for projects where structural members are permanently exposed to weather. For concealed cementitious fire protection specify Type 5GP - see Type 5GP Specifications for details. For exterior cementitious fire protection specify Type 1XR - see Type 1XR specification for details.*

PART 1 – GENERAL

1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the contract documents, including Conditions of Division 1 apply to the work of this section.

1.02 DESCRIPTION OF WORK

A. The work of this section shall include, but is not limited to:

1. Interior fireproofing, concealed from view and direct contact
2. Interior fireproofing, exposed to view and direct contact or abuse
3. Exterior fireproofing, exposed to the elements and contact and possible abuse.

1.03 RELATED WORK

A. Examine all of the contract documents for requirements which affect the work of this section. Other specification sections, which directly relate to the work of this section include, but are not limited to the following:

1. Fire Stopping	Division 07841
2. Insulation	Division 07200
3. Lath and Plaster	Division 09200
4. Structural Steel	Division 05100
5. Steel Joists	Division 05210
6. Metal Floor Decking	Division 05311
7. Metal Roof Decking	Division 05312
8. Mechanical Div. 15	Re: Patching
9. Electrical Div. 16	Re: Patching

1.04 QUALITY ASSURANCE

- A. Installer: Contractor shall be approved by manufacturer, and be experienced in installing specified products, and is approved by the manufacturer of the fireproofing products. A manufacturer's willingness to sell products to an installer engaged by contractor, does not in itself confer qualification on the buyer.
- B. Single Source: Obtain spray applied fireproofing products from a single source for each product required. Provide secondary materials, which are acceptable to the fireproofing manufacturer which, are included in the tested and/or listed designs.

- C. Fire Resistance: Provide fireproofing materials that have been listed and classified by one or more of the following testing authorities: Underwriters Laboratories, Northbrook, IL and/or Underwriters Laboratories, Scarborough, ON; ITS (Warnock Hersey) or other testing and inspecting agency acceptable to the architect and authorities having jurisdiction.
- D. Packaging: All products must be packaged with proper identifications and approval indications acceptable to the testing and/or listing agency.
- E. Asbestos: Manufacturer shall provide Certification that products supplied are 100% asbestos free.
- F. Steel Surfaces: **Structural steel and steel decking shall be unprimed.**
- G. Painted Steel Surfaces: Steel surfaces requiring fireproofing that are painted and/or primed, shall meet UL requirements for application and adhesion characteristics. Provide certifications from fireproofing manufacturer of compatibility of fireproofing and painted systems. Restrictions published by UL shall apply.
- H. Remedial Work: Steel surfaces with incompatible primers or paint shall be either removed, lathed, or otherwise remedied within the requirements of UL, so that adequate and approved bonding can occur, acceptable to authorities having jurisdiction.

1.05 PROJECT CONDITIONS

- A. Environmental Limitations: Do not apply sprayed fireproofing material when ambient or substrate temperatures are 40 deg. F. (4 deg C) or lower, unless temporary heat and protection is provided to maintain temperatures at or above this level for 24 hours before, during and 24 hours after application of fireproofing.
- B. Ventilation: Ventilate building spaces during and after application of fireproofing. Ventilation is necessary during enclosure of spray area site, as a result of inclement weather. Said ventilation shall continue until product has set.
- C. Surfaces to be sprayed: Surfaces to be sprayed must be free of any substance that would impair proper adhesion.
- D. The contractor shall make available to the fireproofing contractor suitable area(s) for permanent locations for mixing and pumping fireproofing. This site must be:
 - 1. Convenient to the structure
 - 2. Be able to accommodate delivery of product
 - 3. Allow for space for truck storage and trailer parking, and for materials and equipment
 - 4. Be well drained
 - 5. Be near a suitable source of potable water of quantity required
 - 6. Have a proper source of electrical power, if required.
 - 7. Provide temporary heat and ventilation to comply with manufacturers recommendations.

1.06 SEQUENCING

- A. Sequence and coordinate application of sprayed fireproofing with other related work specified in other Sections to comply with the following requirements:
 - 1. Provide temporary enclosure for interior applications to prevent deterioration of applied materials exposed to unfavorable environmental conditions.

2. Avoid exposure of fireproofing to unnecessary damage or abrasion.
3. Do not apply fireproofing to metal roof decking until roofing is complete including installation of all air handling systems. Prohibit all roof traffic until application of fireproofing is completed and dry.
4. Do not apply fireproofing until all hangers, clips and other necessary supports are in place, requiring penetration of fireproofing if installed after the application of fireproofing.
5. Ducts, piping and other items that would interfere with the application of fireproofing shall not be installed, until application is completed.

1.07 APPLICATION PARAMETERS

- A. The fireproofing contractor shall be allowed to move freely to apply products as necessary. Materials stored on the floor, shall be protected by the contractor, or relocated if these materials prevent the proper application of fireproofing.
- B. Patching, repairing and cleaning of fireproofing, due to damage done by others, shall be performed by the fireproofing applicator.
- C. After completion of fireproofing, the fireproofing applicator shall remove all equipment, and broom sweep all floor areas of overspray materials.
- D. Application of fireproofing shall not commence until the project is at a stage to allow the applicator to apply product continuously and efficiently, without undue interference and delay by other trades.
- E. Conference: Convene a pre-installation conference to establish a procedure to maintain optimum working conditions and to coordinate this work with related an/or adjacent work.

1.08 SUBMITTALS, REFERENCES AND APPLICABLE STANDARDS

- A. Product Data: Submit manufacturer's product data, installation instructions, use and limitations for each material used, and applicable fire test designs, as listed by approved fire testing organization.
- B. Performance Certification: Submit manufacturer's verification of performance criteria, fire performance and compliance with applicable standards.
- C. Applicable Standards and Test Methods:

Products Submitted shall be tested in accordance with the following test methods:

1. ASTM E 119 Fire Test of Building Construction and Materials
2. ASTM E 84 Test for Surface Burning Characteristics of Building Materials
3. ASTM E 136 Behavior of Materials in a Vertical Tube Furnace at 750 Degrees C
4. ASTM E 605 Thickness and Density of Sprayed Fire Resistive Materials Applied to Structural Members
5. ASTM E 736 Cohesion/Adhesion of Sprayed Fire Resistive Materials Applied to Structural Members
6. ASTM E 759 Effect of Deflection of Sprayed Fire Resistive Materials Applied to Structural Members
7. ASTM E 760 Effect of Impact on Bonding of Sprayed Fire Resistive Materials Applied to Structural Members
8. ASTM E 761 Compressive Strength of Sprayed Fire Resistive Materials Applied to Structural Members

9. ASTM E 859 Air Erosion of Sprayed Fire Resistive Materials Applied to Structural Members
10. ASTM E 937 Corrosion of Steel By Sprayed Fire Resistive Materials Applied to Structural Members
11. ASTM G21 Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi
12. AWCI Technical Manual 12-A, Standard Practice for the Testing and Inspection of Field Applied Sprayed Fire-Resistive Materials; an Annotated Guide

1.09 WARRANTY

A. General Warranty: Submit a written warranty, executed by the contractor and cosigned by the installer, agreeing to repair or replace sprayed fireproofing materials that fall within the specified warranty period.

1. Failures include, but are not limited to cracking, flaking, eroding in excess of specified requirements, peeling and delaminating of sprayed fireproofing from substrates due to defective materials or installation.
2. Not covered in this warranty are failures due to damage by others, such as occupants and owner maintenance personnel, exposure to environmental conditions other than those investigated and approved during fire-response testing, excessive flexing of floor systems, and work on said roof systems, and other causes not reasonable foreseeable under conditions of normal use.

B. Warranty Period: 2 years, from date of substantial completion.

PART 2 - PRODUCTS

A. General: All products shall be cementitious fireproofing materials. Physical properties shall be in accordance with below listed properties. Products shall be a mixture of gypsum and/or cement based materials, with lightweight aggregates to be mixed with water to form a slurry for conveyance and application. Mineral fiber based products not permitted.

2.01 Exposed Interior Fireproofing: For exposed interior applications of sprayed fire-resistive materials, provide manufacturer' s standard products complying with requirements for materials and composition having the following minimum physical properties measured per ASTM standard test methods referenced above in Section 1.08, Part C.

- | | |
|--|---|
| <ol style="list-style-type: none"> 1. E 84: 2. E 136: 3. E 605: 4. E 736: 5. E 759: 6. E 760: 7. E 761: 8. E 859: 9. E 937: 10. D 2240: 11. G 21: | <p>Flame Spread 0, and Smoke Developed 0.</p> <p>Passes, and is determined non - combustible</p> <p>Density shall be a minimum of 22 pcf.</p> <p>Cohesion/Adhesion shall be >1000 psf, with 750 psf minimum acceptable level; if primed steel is used, comply with requirements published by U.L.I. Contact AD for Details</p> <p>No cracking, spalling or delamination</p> <p>Impact: No delamination, cracking or spalling</p> <p>Compression shall be >15,000 lb/ft.</p> <p>Erosion shall be 0.00 gr/sq.ft. maximum</p> <p>Corrosion: No evidence of corrosion allowed</p> <p>Shore D Hardness shall be >20</p> <p>Mold Resistance: No Growth</p> |
|--|---|

A. Exposed interior fire protection shall include, but are not limited to the following areas:

1. Stairwell columns and beams
2. Elevator shafts structural steel
3. Mechanical room columns

B. Manufacturers:

1. AD Fire Protection Systems (a licensee of Southwest Vermiculite) - Type 7GP
2. or equal

2.02 Miscellaneous Materials: Provide the following materials as standard with each of the fireproofing systems, as recommended by the manufacturer for each condition and substrate.

A. Primers: It is not recommended that any structural steel primers are used on any steel surfaces, unless tested and listed by ULI in designs proposed to be used. Compatible primers may be used, providing the fireproofing manufacturer can verify such compatibility in accordance with UL requirements.

B. Adhesives: Provide adhesives as necessary, to comply with manufacturer requirements for adhesion of fireproofing. Acceptable adhesives are:

1. Type DK Spatter Coat
2. TC 55 water based acrylic adhesive
3. Other, only as approved by A/D Fire Protection Systems

C. Reinforcements: Provide fiberglass mesh or wire lath for areas where adhesion is not compatible and for application of fireproofing to steel joists.

D. Mold Inhibitor: Provide factory added mold inhibitor tested in accordance with ASTM G 21 for areas such as hospitals, testing laboratories, health facilities and other areas of hygienic requirements.

E. Top Coats: Use as required and recommended by fireproofing manufacturer or compatible products.

PART 3 – EXECUTION

3.01 Pre-Installation Examination: The applicator and the contractor shall examine surfaces to be fire protected, and determined if the surfaces are satisfactory. Substrate conditions must comply with the following:

A. Substrates must be free of grease, oil, rolling compounds, incompatible primers, loose mill scale, dirt or any other foreign matter which would prevent proper bonding of fireproofing. Structural steel shall be unprimed. Steel roof and floor decking shall be galvanized only.

B. Any objects such as hangers, piping attachments, and other suspended retainer devices shall be properly secured.

C. Ducts, piping, and other equipment shall not be placed or suspended until the Fireprotection materials are in place.

3.02 Preparation:

- A. Clean any substrate not ready to receive fireproofing. Consult with manufacturer if conditions exist not easily remedied.
- B. Apply adhesives as necessary.
- C. Cover all work subject to oversprays during application. Provide temporary enclosure when necessary to temporarily confine fireproofing and protect the environment.
- D. Assure maintenance of ambient temperatures, and/or heat and ventilation when required.

3.03 Installation, General

- A. Comply with manufacturers written application instructions and procedures for mixing, conveying and applying products, in accordance with the types of recommended equipment, admixtures and specific procedures regarding special conditions.
- B. Coat substrates with adhesives if necessary.
- C. Extend fireproofing materials in full thickness per approved design, to be protected. Unless otherwise recommended, install fireproofing complete in each area, prior to another.
- D. Provide a uniform surface matching UL requirements for designs approved. Apply products at the minimum densities required, or greater.
- E. Cure fireproofing to prevent premature drying; protect from freezing as listed in Section 1.05 of this specification.
- F. Exposed to View Applications: Where exposed to view, provide appearance of Fireprotection as follows:
 - a) Provide a troweled surface of appearance previously determined prior to installation
 - b) Surfaces shall be within tolerances of 1/16 inch
 - c) Mask edges of termination's so as to achieve neat and sharp edges.

3.04 Field Quality Control:

- A. Testing Agency: The owner shall engage and the contractor and applicator shall approve a qualified independent testing agency to perform field quality inspections of applied fireproofing, and prepare reports.
 - a) Testing shall be done in accordance with the AWCI "Technical Manual 12 - A, Standard Practice for the Testing and Inspection of Field Applied Sprayed Fire-Resistive Materials; an Annotated Guide" and ASTM E 605.
 - b) Tests shall be done on thickness, density and adhesion
 - c) Variances shall be corrected with the testing agency present, and when the applicator is performing work in the same area, to allow for expedient corrections.
 - d) A schedule of tests to be performed shall be agreed upon by applicator, contractor and testing agency.

3.05 Cleaning and Repair:

A. After completion of each day's work, the applicator shall broom clean the area fireproofed. Areas not to receive fireproofing but are finished surfaces shall be masked.

B. All patching of damaged fireproofing shall be completed by applicator.

3.06 Schedule:

A. Fire resistance rating shall be in hours as listed below

STRUCTURAL COMPONENT	HOURS REQUIRED	UL DESIGN
FLOOR ASSEMBLY	_____	
ROOF ASSEMBLY	_____	
COLUMNS, SPANDREL	_____	
COLUMNS, INTERIOR	_____	
PRIMARY BEAMS	_____	
SECONDARY BEAMS	_____	
TRUSSES	_____	
ROOF DECK, BEAMS, JOISTS	_____	

B. List below other provisions not covered above: _____

3.7 Restrained and Unrestrained Conditions

Underwriters Laboratories Inc. (ULI) has published a guide that in part, allows for determination of thermally restrained and unrestrained conditions in structures. In fire tests, restraint conditions are used as a standard. The publication of ULI that describes these conditions is in their "Fire Tests of Building Construction and Materials – UL 263. Copies available upon request.

Definitions:

- A. Thermal Restraint: Expansion of a load-carrying element due to exposure to fire is resisted by forces that develop external to the element.
- B. Thermal Unrestraint: The load-carrying element is free to expand as the result of exposure to fire and rotate on supports.

Note: A/D Fire Protection Systems is a licensed producer of products listed in the UL Directories under "Southwest Vermiculite Inc."

END OF THIS SECTION

AD Fire Protection Systems

Frank Neuwirth, Division Manager
Southwest Products Group

07810 -8

spec 2004 section 07810